



November 21, 2024

William Kotas
Intertek PSI
17 British American Boulevard
Latham, NY 12110

RE: Project: HUDSON FALLS CSD MIDDLE SCHOOL
Pace Project No.: 70321594

Dear William Kotas:

Enclosed are the analytical results for sample(s) received by the laboratory on November 07, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads "Lori Beyer".

Lori A. Beyer
lori.beyer@pacelabs.com
516-370-6014
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70321594001	MS-CRM	Drinking Water	10/31/24 06:25	11/07/24 07:00
70321594002	MS-KITC	Drinking Water	10/31/24 06:20	11/07/24 07:00
70321594003	MS-POTI	Drinking Water	10/31/24 06:20	11/07/24 07:00
70321594004	MS-KITF	Drinking Water	10/31/24 06:20	11/07/24 07:00
70321594005	MS-WSA	Drinking Water	10/31/24 06:20	11/07/24 07:00
70321594006	MS-WSB	Drinking Water	10/31/24 06:20	11/07/24 07:00
70321594007	MS-WSC	Drinking Water	10/31/24 06:15	11/07/24 07:00
70321594008	MS-OFFICE 1	Drinking Water	10/31/24 06:25	11/07/24 07:00
70321594009	MS-NURSE A	Drinking Water	10/31/24 06:25	11/07/24 07:00
70321594010	MS-NURSE B	Drinking Water	10/31/24 06:25	11/07/24 07:00
70321594011	MS-B6-A	Drinking Water	10/31/24 07:25	11/07/24 07:00
70321594012	MS-B6-B	Drinking Water	10/31/24 07:25	11/07/24 07:00
70321594013	MS-B6-C	Drinking Water	10/31/24 07:25	11/07/24 07:00
70321594014	MS-B6-BB-A	Drinking Water	10/31/24 07:25	11/07/24 07:00
70321594015	MS-B6-BB-B	Drinking Water	10/31/24 07:25	11/07/24 07:00
70321594016	MS-B6-BB-C	Drinking Water	10/31/24 07:25	11/07/24 07:00
70321594017	MS-B6-BB-D	Drinking Water	10/31/24 07:25	11/07/24 07:00
70321594018	MS-B18	Drinking Water	10/31/24 06:40	11/07/24 07:00
70321594019	MS-F-DF-BF	Drinking Water	10/31/24 06:25	11/07/24 07:00
70321594020	MS-A-DF	Drinking Water	10/31/24 06:30	11/07/24 07:00
70321594021	MS-D4-A	Drinking Water	10/31/24 06:15	11/07/24 07:00
70321594022	MS-D4-B	Drinking Water	10/31/24 06:15	11/07/24 07:00
70321594023	MS-D4-C	Drinking Water	10/31/24 06:15	11/07/24 07:00
70321594024	MS-D3-A	Drinking Water	10/31/24 06:15	11/07/24 07:00
70321594025	MS-D3-B	Drinking Water	10/31/24 06:15	11/07/24 07:00
70321594026	MS-D3-C	Drinking Water	10/31/24 06:15	11/07/24 07:00
70321594027	MS-HW 1	Drinking Water	10/31/24 06:20	11/07/24 07:00
70321594028	MS-HW 2	Drinking Water	10/31/24 06:20	11/07/24 07:00
70321594029	MS-NURSE-S	Drinking Water	10/31/24 06:25	11/07/24 07:00
70321594030	MS-E-DF	Drinking Water	10/31/24 06:25	11/07/24 07:00
70321594031	MS-GLR B	Drinking Water	10/31/24 06:30	11/07/24 07:00
70321594032	MS-GLR C	Drinking Water	10/31/24 06:30	11/07/24 07:00
70321594033	MS-GLR D	Drinking Water	10/31/24 06:30	11/07/24 07:00
70321594034	MS-G COACH	Drinking Water	10/31/24 06:30	11/07/24 07:00
70321594035	MS-B COACH	Drinking Water	10/31/24 06:30	11/07/24 07:00
70321594036	MS-BLR A	Drinking Water	10/31/24 06:30	11/07/24 07:00
70321594037	MS-BLRA B	Drinking Water	10/31/24 06:30	11/07/24 07:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70321594038	MS-A9	Drinking Water	10/31/24 06:35	11/07/24 07:00
70321594039	MS-B7-A	Drinking Water	10/31/24 07:20	11/07/24 07:00
70321594040	MS-B7-B	Drinking Water	10/31/24 07:20	11/07/24 07:00
70321594041	MS-C2	Drinking Water	10/31/24 06:25	11/07/24 07:00
70321594042	MS-GLR-A	Drinking Water	10/31/24 06:30	11/07/24 07:00
70321594043	MS-A-DF-2	Drinking Water	10/31/24 07:25	11/07/24 07:00
70321594044	MS-B-DF-1	Drinking Water	10/31/24 07:25	11/07/24 07:00
70321594045	MS-B-DF-1-BF	Drinking Water	10/31/24 07:25	11/07/24 07:00
70321594046	MS-B-DF-2	Drinking Water	10/31/24 07:25	11/07/24 07:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70321594001	MS-CRM	EPA 200.8	JP2	1
70321594002	MS-KITC	EPA 200.8	JP2	1
70321594003	MS-POTI	EPA 200.8	JP2	1
70321594004	MS-KITF	EPA 200.8	JP2	1
70321594005	MS-WSA	EPA 200.8	JP2	1
70321594006	MS-WSB	EPA 200.8	JP2	1
70321594007	MS-WSC	EPA 200.8	JP2	1
70321594008	MS-OFFICE 1	EPA 200.8	JP2	1
70321594009	MS-NURSE A	EPA 200.8	JP2	1
70321594010	MS-NURSE B	EPA 200.8	JP2	1
70321594011	MS-B6-A	EPA 200.8	JP2	1
70321594012	MS-B6-B	EPA 200.8	JP2	1
70321594013	MS-B6-C	EPA 200.8	JP2	1
70321594014	MS-B6-BB-A	EPA 200.8	JP2	1
70321594015	MS-B6-BB-B	EPA 200.8	JP2	1
70321594016	MS-B6-BB-C	EPA 200.8	JP2	1
70321594017	MS-B6-BB-D	EPA 200.8	JP2	1
70321594018	MS-B18	EPA 200.8	JP2	1
70321594019	MS-F-DF-BF	EPA 200.8	JP2	1
70321594020	MS-A-DF	EPA 200.8	JP2	1
70321594021	MS-D4-A	EPA 200.8	JP2	1
70321594022	MS-D4-B	EPA 200.8	JP2	1
70321594023	MS-D4-C	EPA 200.8	JP2	1
70321594024	MS-D3-A	EPA 200.8	JP2	1
70321594025	MS-D3-B	EPA 200.8	JP2	1
70321594026	MS-D3-C	EPA 200.8	JP2	1
70321594027	MS-HW 1	EPA 200.8	JP2	1
70321594028	MS-HW 2	EPA 200.8	JP2	1
70321594029	MS-NURSE-S	EPA 200.8	JP2	1
70321594030	MS-E-DF	EPA 200.8	JP2	1
70321594031	MS-GLR B	EPA 200.8	JP2	1
70321594032	MS-GLR C	EPA 200.8	JP2	1
70321594033	MS-GLR D	EPA 200.8	JP2	1
70321594034	MS-G COACH	EPA 200.8	JP2	1
70321594035	MS-B COACH	EPA 200.8	JP2	1
70321594036	MS-BLR A	EPA 200.8	JP2	1
70321594037	MS-BLRA B	EPA 200.8	JP2	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70321594038	MS-A9	EPA 200.8	JP2	1
70321594039	MS-B7-A	EPA 200.8	JP2	1
70321594040	MS-B7-B	EPA 200.8	JP2	1
70321594041	MS-C2	EPA 200.8	JP2	1
70321594042	MS-GLR-A	EPA 200.8	JP2	1
70321594043	MS-A-DF-2	EPA 200.8	JP2	1
70321594044	MS-B-DF-1	EPA 200.8	JP2	1
70321594045	MS-B-DF-1-BF	EPA 200.8	JP2	1
70321594046	MS-B-DF-2	EPA 200.8	JP2	1

PACE-MV = Pace Analytical Services - Melville

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: MS-CRM								
Lab ID: 70321594001								
Collected: 10/31/24 06:25								
Received: 11/07/24 07:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		11/20/24 20:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: MS-KITC		Lab ID: 70321594002		Collected: 10/31/24 06:20	Received: 11/07/24 07:00	Matrix: Drinking Water		
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		11/20/24 20:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-POTI		Lab ID: 70321594003	Collected: 10/31/24 06:20	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 20:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: MS-KITF								
Lab ID: 70321594004								
Collected: 10/31/24 06:20								
Received: 11/07/24 07:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.8	ug/L	1.0	1		11/20/24 20:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-WSA		Lab ID: 70321594005	Collected: 10/31/24 06:20	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-WSB		Lab ID: 70321594006	Collected: 10/31/24 06:20	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.6	ug/L	1.0	1		11/20/24 21:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-WSC		Lab ID: 70321594007	Collected: 10/31/24 06:15	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-OFFICE 1		Lab ID: 70321594008	Collected: 10/31/24 06:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-NURSE A	Lab ID: 70321594009	Collected: 10/31/24 06:25	Received: 11/07/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/20/24 21:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-NURSE B		Lab ID: 70321594010	Collected: 10/31/24 06:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B6-A	Lab ID: 70321594011	Collected: 10/31/24 07:25	Received: 11/07/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/20/24 21:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B6-B		Lab ID: 70321594012	Collected: 10/31/24 07:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		11/20/24 21:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B6-C		Lab ID: 70321594013	Collected: 10/31/24 07:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		11/20/24 21:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B6-BB-A		Lab ID: 70321594014	Collected: 10/31/24 07:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B6-BB-B		Lab ID: 70321594015	Collected: 10/31/24 07:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B6-BB-C		Lab ID: 70321594016	Collected: 10/31/24 07:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		11/20/24 21:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: MS-B6-BB-D								
Lab ID: 70321594017								
Collected: 10/31/24 07:25								
Received: 11/07/24 07:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		11/20/24 21:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: MS-B18								
Lab ID: 70321594018								
Collected: 10/31/24 06:40								
Received: 11/07/24 07:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		11/20/24 21:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-F-DF-BF		Lab ID: 70321594019	Collected: 10/31/24 06:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-A-DF		Lab ID: 70321594020	Collected: 10/31/24 06:30	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-D4-A		Lab ID: 70321594021	Collected: 10/31/24 06:15	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.6	ug/L	1.0	1		11/20/24 21:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: MS-D4-B								
Lab ID: 70321594022								
Collected: 10/31/24 06:15								
Received: 11/07/24 07:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.9	ug/L	1.0	1		11/20/24 21:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-D4-C		Lab ID: 70321594023	Collected: 10/31/24 06:15	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.9	ug/L	1.0	1		11/20/24 21:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-D3-A		Lab ID: 70321594024	Collected: 10/31/24 06:15	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-D3-B		Lab ID: 70321594025	Collected: 10/31/24 06:15	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-D3-C		Lab ID: 70321594026	Collected: 10/31/24 06:15	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 21:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: MS-HW 1								
Lab ID: 70321594027								
Collected: 10/31/24 06:20								
Received: 11/07/24 07:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		11/20/24 21:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-HW 2		Lab ID: 70321594028	Collected: 10/31/24 06:20	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		11/20/24 22:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-NURSE-S		Lab ID: 70321594029	Collected: 10/31/24 06:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		11/20/24 22:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-E-DF		Lab ID: 70321594030	Collected: 10/31/24 06:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-GLR B		Lab ID: 70321594031	Collected: 10/31/24 06:30	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-GLR C		Lab ID: 70321594032	Collected: 10/31/24 06:30	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-GLR D		Lab ID: 70321594033	Collected: 10/31/24 06:30	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-G COACH		Lab ID: 70321594034	Collected: 10/31/24 06:30	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B COACH		Lab ID: 70321594035	Collected: 10/31/24 06:30	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-BLR A		Lab ID: 70321594036	Collected: 10/31/24 06:30	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-BLRA B		Lab ID: 70321594037	Collected: 10/31/24 06:30	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-A9		Lab ID: 70321594038	Collected: 10/31/24 06:35	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B7-A		Lab ID: 70321594039	Collected: 10/31/24 07:20	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B7-B		Lab ID: 70321594040	Collected: 10/31/24 07:20	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		11/20/24 22:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-C2		Lab ID: 70321594041	Collected: 10/31/24 06:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-GLR-A		Lab ID: 70321594042	Collected: 10/31/24 06:30	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-A-DF-2		Lab ID: 70321594043	Collected: 10/31/24 07:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B-DF-1		Lab ID: 70321594044	Collected: 10/31/24 07:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B-DF-1-BF		Lab ID: 70321594045	Collected: 10/31/24 07:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/20/24 22:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Sample: MS-B-DF-2		Lab ID: 70321594046	Collected: 10/31/24 07:25	Received: 11/07/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		11/20/24 22:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

QC Batch:	371760	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70321594001, 70321594002, 70321594003

METHOD BLANK: 1944726 Matrix: Water
 Associated Lab Samples: 70321594001, 70321594002, 70321594003

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/20/24 20:04	

LABORATORY CONTROL SAMPLE: 1944727

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.5	101	85-115	

MATRIX SPIKE SAMPLE: 1944729

Parameter	Units	70321592039 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	52.8	105	70-130	

MATRIX SPIKE SAMPLE: 1944731

Parameter	Units	70321592040 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	8.5	50	60.2	103	70-130	

SAMPLE DUPLICATE: 1944728

Parameter	Units	70321592039 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

SAMPLE DUPLICATE: 1944730

Parameter	Units	70321592040 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	8.5	8.7	2	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

QC Batch:	371762	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70321594004, 70321594005, 70321594006, 70321594007, 70321594008, 70321594009, 70321594010, 70321594011, 70321594012, 70321594013, 70321594014, 70321594015, 70321594016, 70321594017, 70321594018, 70321594019, 70321594020, 70321594021, 70321594022, 70321594023		

METHOD BLANK:	1944739	Matrix:	Water
Associated Lab Samples:	70321594004, 70321594005, 70321594006, 70321594007, 70321594008, 70321594009, 70321594010, 70321594011, 70321594012, 70321594013, 70321594014, 70321594015, 70321594016, 70321594017, 70321594018, 70321594019, 70321594020, 70321594021, 70321594022, 70321594023		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/20/24 20:54	

LABORATORY CONTROL SAMPLE:	1944740					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.1	102	85-115	

MATRIX SPIKE SAMPLE:	1944742						
Parameter	Units	70321594004 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.8	50	55.1	102	70-130	

MATRIX SPIKE SAMPLE:	1944744						
Parameter	Units	70321594005 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	50.8	101	70-130	

SAMPLE DUPLICATE:	1944741					
Parameter	Units	70321594004 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	3.8	3.8	0	20	

SAMPLE DUPLICATE:	1944743					
Parameter	Units	70321594005 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

QC Batch:	371764	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70321594024, 70321594025, 70321594026, 70321594027, 70321594028, 70321594029, 70321594030, 70321594031, 70321594032, 70321594033, 70321594034, 70321594035, 70321594036, 70321594037, 70321594038, 70321594039, 70321594040, 70321594041, 70321594042, 70321594043		

METHOD BLANK:	1944749	Matrix:	Water
Associated Lab Samples:	70321594024, 70321594025, 70321594026, 70321594027, 70321594028, 70321594029, 70321594030, 70321594031, 70321594032, 70321594033, 70321594034, 70321594035, 70321594036, 70321594037, 70321594038, 70321594039, 70321594040, 70321594041, 70321594042, 70321594043		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/20/24 21:42	

LABORATORY CONTROL SAMPLE:	1944750					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.0	102	85-115	

MATRIX SPIKE SAMPLE:	1944752						
Parameter	Units	70321594024 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	51.5	101	70-130	

MATRIX SPIKE SAMPLE:	1944754						
Parameter	Units	70321594025 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	50.0	100	70-130	

SAMPLE DUPLICATE:	1944751					
Parameter	Units	70321594024 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

SAMPLE DUPLICATE:	1944753					
Parameter	Units	70321594025 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

QC Batch:	371766	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70321594044, 70321594045, 70321594046

METHOD BLANK: 1944757 Matrix: Water

Associated Lab Samples: 70321594044, 70321594045, 70321594046

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/20/24 22:32	

LABORATORY CONTROL SAMPLE: 1944758

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.5	101	85-115	

MATRIX SPIKE SAMPLE: 1944760

Parameter	Units	70321594044 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	50.1	100	70-130	

MATRIX SPIKE SAMPLE: 1944762

Parameter	Units	70321594045 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.4	97	70-130	

SAMPLE DUPLICATE: 1944759

Parameter	Units	70321594044 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

SAMPLE DUPLICATE: 1944761

Parameter	Units	70321594045 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: HUDSON FALLS CSD MIDDLE SCHOOL

Pace Project No.: 70321594

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70321594001	MS-CRM	EPA 200.8	371760		
70321594002	MS-KITC	EPA 200.8	371760		
70321594003	MS-POTI	EPA 200.8	371760		
70321594004	MS-KITF	EPA 200.8	371762		
70321594005	MS-WSA	EPA 200.8	371762		
70321594006	MS-WSB	EPA 200.8	371762		
70321594007	MS-WSC	EPA 200.8	371762		
70321594008	MS-OFFICE 1	EPA 200.8	371762		
70321594009	MS-NURSE A	EPA 200.8	371762		
70321594010	MS-NURSE B	EPA 200.8	371762		
70321594011	MS-B6-A	EPA 200.8	371762		
70321594012	MS-B6-B	EPA 200.8	371762		
70321594013	MS-B6-C	EPA 200.8	371762		
70321594014	MS-B6-BB-A	EPA 200.8	371762		
70321594015	MS-B6-BB-B	EPA 200.8	371762		
70321594016	MS-B6-BB-C	EPA 200.8	371762		
70321594017	MS-B6-BB-D	EPA 200.8	371762		
70321594018	MS-B18	EPA 200.8	371762		
70321594019	MS-F-DF-BF	EPA 200.8	371762		
70321594020	MS-A-DF	EPA 200.8	371762		
70321594021	MS-D4-A	EPA 200.8	371762		
70321594022	MS-D4-B	EPA 200.8	371762		
70321594023	MS-D4-C	EPA 200.8	371762		
70321594024	MS-D3-A	EPA 200.8	371764		
70321594025	MS-D3-B	EPA 200.8	371764		
70321594026	MS-D3-C	EPA 200.8	371764		
70321594027	MS-HW 1	EPA 200.8	371764		
70321594028	MS-HW 2	EPA 200.8	371764		
70321594029	MS-NURSE-S	EPA 200.8	371764		
70321594030	MS-E-DF	EPA 200.8	371764		
70321594031	MS-GLR B	EPA 200.8	371764		
70321594032	MS-GLR C	EPA 200.8	371764		
70321594033	MS-GLR D	EPA 200.8	371764		
70321594034	MS-G COACH	EPA 200.8	371764		
70321594035	MS-B COACH	EPA 200.8	371764		
70321594036	MS-BLR A	EPA 200.8	371764		
70321594037	MS-BLRA B	EPA 200.8	371764		
70321594038	MS-A9	EPA 200.8	371764		
70321594039	MS-B7-A	EPA 200.8	371764		
70321594040	MS-B7-B	EPA 200.8	371764		
70321594041	MS-C2	EPA 200.8	371764		
70321594042	MS-GLR-A	EPA 200.8	371764		
70321594043	MS-A-DF-2	EPA 200.8	371764		
70321594044	MS-B-DF-1	EPA 200.8	371766		
70321594045	MS-B-DF-1-BF	EPA 200.8	371766		
70321594046	MS-B-DF-2	EPA 200.8	371766		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



Pace* Location Requested (City/State):
 Pace Analytical Long Island NY
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: Intertek-PSI
 Street Address: 17 British American Blvd, Latham, NY 12210

Contact/Report To: William Kotas
 Phone #: (518) 377-9841
 E-Mail: william.kotas@intertek.com
 Cc E-Mail:

Customer Project #: 08215514
 Project Name: HUDSON FALLS CENTRAL SCHOOL DISTRICT

Invoice To: PSI Latham Accounts Payable
 Invoice E-Mail: LathamAR@intertek.com

Site Collection Info/Facility ID (as applicable):

Middle School

Purchase Order # (if applicable):

Quote #: CR-BOCES RCO #23-057

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

[] Level II [] Level III [] Level IV
 [] EQUIS
 [] Other:

Rush (Pre-approval required):

[] 2 Day [] 3 day [] 5 day [] Other:

Date Results Requested: Standard 10 business day

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): [] Yes [] No

Analysis:

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

WO#: 70321594



Specify Container Size **
 Identify Container Preservative Type***
 Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 60mL vial, (7) EnCore, (8) TerraCore, (9) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) NaOH, (11) Other

Proj. Mgr:
 Lord Beyer
 AcctNum / Client ID:
 AR 70-102260
 Table #:
 Profile / Template:
 10367
 Prelg / Bottle Ord. ID:

Lab Use Only
 Preservation non-conformance identified for sample.

Customer Sample ID	Matrix *	Comp / Grab	Collected		Composite End		Res. CL2	Number & Type of Containers		Sample Comment
			Date	Time	Date	Time		Plastic	Glass	
MS-CRM	DW	G	10/31/24	6:35				1		X
MS-KITC			10/31/24	6:30						
MS-POT1			10/31/24	6:30						
MS-KITF			10/31/24	6:30						
MS-WSA			10/31/24	6:30						
MS-WSB			10/31/24	6:30						
MS-WSC			10/31/24	6:15						
MS-OFFICE 1			10/31/24	6:25						
MS-NURSE A			10/31/24	6:25						
MS-NURSE B			10/31/24	6:25						

Additional Instructions from Pace*:
 Collected By: Richard Paszkiewicz
 Printed Name: Richard Paszkiewicz
 Signature:

Received by/Company (Signature)	Date/Time	Received by/Company (Signature)	Date/Time	Received by/Company (Signature)	Date/Time	Received by/Company (Signature)	Date/Time
<i>Richard Paszkiewicz</i>	10/31/24 10:45AM	<i>Pre</i>	10:45				
<i>Dee PACE</i>	11/24	<i>Dee PACE</i>	7:00				

Customer Remarks / Special Conditions / Possible Hazards:
 Lead
 Tracking Number:
 Delivered by: [] In-Person [] Courier
 [] FedEx [] UPS [] Other
 Page: 1 of 5

CHAIN-OF-CUSTODY Analytical Request Document
 Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

WO#: 70321594

PM: LAB Due Date: 11/21/24
CLIENT: INTER-LATHAM



Company Name: **Intertek-PSI**
 Street Address: **17 British American Blvd, Latham, NY 12210**
 Customer Project #: **08215514**
 Project Name: **HUDSON FALLS CENTRAL SCHOOL DISTRICT**
 Site Collection Info/Facility ID (as applicable):
Middle School

Contact/Report To: **William Kotas**
 Phone #: **(518) 377-9841**
 E-Mail: william.kotas@intertek.com
 Cc E-Mail:
 Invoice To: **PSI Latham Accounts Payable**
 Invoice E-Mail: LathamAR@intertek.com
 Purchase Order # (if applicable):
 Quote #: **CR-BOCES RCO #23-057**

Time Zone Collected: [] AK [] PT [] MT [] CT [X] ET
 Data Deliverables:
 [] Level II [] Level III [] Level IV
 [] EQUIS
 [] Other:
 Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**
 Rush (Pre-approval required):
 [] 2 Day [] 3 day [] 5 day [] Other:
 Date Results Requested: **Standard 10 business day**
 Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Specify Container Size **
 Identify Container Preservative Type***
 Analysis Requested

Matrix *	Comp / Grab	Collected (or Composite Start) Date	Time	Composite End Date	Time	Res. CLZ	Number & Type of Containers	Plastic	Glass
DW	G	10/31/24	7:25				1		
MS-B6-A		10/31/24	7:25						
MS-B6-B		10/31/24	7:25						
MS-B6-C		10/31/24	7:25						
MS-B-BB-A		10/31/24	7:25						
MS-B-BB-B		10/31/24	7:25						
MS-B-BB-C		10/31/24	7:25						
MS-B-BB-D		10/31/24	7:25						
MS-B18		10/31/24	6:40						
MS-E-DF-BF		10/31/24	6:25						
MS-A-DF		10/31/24	6:30						

Additional Instructions from Pace*:
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)
 Tracking Number:
 Date/Time: 11/17/24 7:00
 Date/Time: 11/17/24 7:00
 Date/Time:
 Date/Time:

Customer Sample ID
 MS-B6-A
 MS-B6-B
 MS-B6-C
 MS-B-BB-A
 MS-B-BB-B
 MS-B-BB-C
 MS-B-BB-D
 MS-B18
 MS-E-DF-BF
 MS-A-DF

Collected By: **Richard Paszkiewicz**
 Printed Name: Richard Paszkiewicz
 Signature:
 Received by/Company: (Signature) **Pace**
 Received by/Company: (Signature) **B. Davis**
 Received by/Company: (Signature) **William Deay**
 Received by/Company: (Signature)
 Received by/Company: (Signature)

Company Name: Intertek-PSI
Street Address: 17 British American Blvd, Latham, NY 12210
Contact/Report To: William Kotas
Phone #: (518) 377-9841
E-Mail: william.kotas@intertek.com
Cc E-Mail:

Customer Project #: 08215514
Project Name: HUDSON FALLS CENTRAL SCHOOL DISTRICT
Invoice To: PSI Latham Accounts Payable
Invoice E-Mail: LathamAR@intertek.com

Site Collection Info/Facility ID (as applicable):
 Middle School
 CR-BOCES RCO #23-057

Time Zone Collected: [] AK [] MT [] CT [] ET
Data Deliverables:
 [] Level II [] Level III [] Level IV
 [] EQUUS
 [] Other

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW
Rush (Pre-approval required):
 [] 2 Day [] 3 day [] 5 day [] Other
Date Results Requested: Standard 10 business day

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Field Filtered (if applicable): [] Yes [] No

Analysis:

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End Date	Res. CL2	Number & Type of Containers	
			Date	Time			Plastic	Glass
MS-D4-A	DW	G	10/31/24	6:15			1	X
MS-D4-B			10/31/24	6:15				
MS-D4-C			10/31/24	6:15				
MS-D3-A			10/31/24	6:15				
MS-D3-B			10/31/24	6:15				
MS-D3-C			10/31/24	6:15				
MS-HW1			10/31/24	6:20				
MS-HW2			10/31/24	6:20				
MS-NURSE-S			10/31/24	6:25				
MS-E-DF			10/31/24	6:25				

Customer Remarks / Special Conditions / Possible Hazards:
 Lead


Collected By: Richard Paszkiewicz
Printed Name: Richard Paszkiewicz
Signature:

Received by/Company (Signature): [Signature]
Date/Time: 11/6/24 10:45AM
Received by/Company (Signature): [Signature]
Date/Time: 11/7/24 9:00

Tracking Number: 11610145
Delivered by: [] In-Person [] Courier
 [] FedEx [] UPS [] Other

Date/Time:
Received by/Company (Signature):
Date/Time:

Page: 3 **of** 5



Pace* Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

Company Name: **Intertek-PSI**
Street Address: **17 British American Blvd, Latham, NY 12210**

Customer Project #: **08215514**
Project Name: **HUDSON FALLS CENTRAL SCHOOL DISTRICT**

Site Collection Info/Facility ID (as applicable):
Middle School

Time Zone Collected: [] AK [] PT [] MT [] CT [X] ET
Data Deliverables:
[] Level II [] Level III [] Level IV
[] EQUIS
[] Other

Rush (Pre-approval required):
[] 2 Day [] 3 day [] 5 day [] Other

Date Results Requested:
Standard 10 business day

Country / State origin of sample(s): **New York**
Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Contact/Report To: **William Kotas**
Phone #: **(518) 377-9841**
E-Mail: **william.kotas@intertek.com**
CC E-Mail:

Invoice To: **PSI Latham Accounts Payable**
Invoice E-Mail: **LathamAR@intertek.com**
Purchase Order # (if applicable):
Quote #: **CR-BOCES RCO #23-057**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Specify Container Size **
125mL, (5) 100mL, (6) 40mL vial, (7) Encore, (8) TerraCore, (9) Other

Identify Container Preservative Type***
H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Analysis Requested


Lab Use Only
Proj. Mgr: **Loth Beyer**
AcctNum / Client ID: **AR 70-102260**
Table #: **10367**
Profile / Template:
Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample

Scan QR Code for instructions

Additional Instructions from Pace*:
Coolers: Thermometer ID: Obs. Temp. (°C) Correction Factor (°C) Corrected Temp. (°C)

Tracking Number:
Date/Time: **11/6/24 10:45 AM**
Date/Time: **11/24/24 7:00**
Delivered by: [] In-Person [] Courier
[] FedEx [] UPS [] Other
Page: **4** of **5**



LAB USE ONLY - Affix Workorder/Login Label Here

200.8 Drinking Water (Pb only)

Sample Comment

Number & Type of Containers
Plastic Glass

Res. CL2

Composite End Date Time

Collected (or Composite Start) Date Time

Matrix* Comp / Grab

Customer Sample ID
MS-6LR B
MS-6LR C
MS-6LR D
MS-G COACH
MS-B COACH
MS-BLRA
MS-BLR B
MS-A9
MS-B7-A
MS-B7-B

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Collected By: **Richard Paszkiewicz**
Printed Name: **Richard Paszkiewicz**
Signature:

Received by/Company: (Signature)
David Amichini
Date/Time: **11/6/24 10:45 AM**

Received by/Company: (Signature)
William Beyer
Date/Time: **11/24/24 7:00**

Received by/Company: (Signature)

Received by/Company: (Signature)

Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/>

Page 52 of 65

ENV-FRM-CORQ-0019_v01_082123 ©



Pace* Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

Company Name: **Intertek-PSI**
Street Address: **17 British American Blvd, Latham, NY 12210**

Customer Project #: **08215514**
Project Name: **HUDSON FALLS CENTRAL SCHOOL DISTRICT**

Site Collection Info/Facility ID (as applicable):
Middle School

Time Zone Collected: AK PT MT CT ET

Data Deliverables:
 Level II Level III Level IV
 EQUIS
 Other _____

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Contact/Report To: **William Kotas**
Phone #: **(518) 377-9841**
E-Mail: william.kotas@intertek.com
Cc E-Mail:

Invoice To: **PSI Latham Accounts Payable**
Invoice E-Mail: LathamAR@intertek.com

Purchase Order # (if applicable):
Quote #: **CR-BOCES RCO #23-057**

County/State origin of sample(s): **New York**

Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**

Rush (Pre-approval required):
 2 Day 3 day 5 day Other _____

Date Results Requested: **Standard 10 business day**
Field Filtered (if applicable): Yes No
Analysis:

DW PWSID # or WW Permit # as applicable:

Number & Type of Containers
Plastic: **1** Glass:

Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End		Res. CL2	Number & Type of Containers Plastic: Glass
		Date	Time	Date	Time		
DW	G	10/31/24	6:25				1
MS-C2		10/31/24	6:30				
MS-GLR-A		10/31/24	7:35				
MS-A-DF-2		10/31/24	7:35				
MS-B-DF-1		10/31/24	7:25				
MS-B-DF-1-BF		10/31/24	7:25				
MS-DF-2		10/31/24	7:25				

Customer Remarks / Special Conditions / Possible Hazards:
Lead

Collected By: **Richard Paszkiewicz**
Printed Name: **Richard Paszkiewicz**
Signature:

Date/Time: **11/6/24 10:45 AM** Received by/Company: **Pace**
Date/Time: **11/7/24 10:10 AM** Received by/Company: **Richard Paszkiewicz**
Date/Time: **11/7/24 3:00** Received by/Company: **Day PACEY**
Date/Time: Received by/Company: **Richard Paszkiewicz**
Date/Time: Received by/Company: **Richard Paszkiewicz**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here



Scan QR Code for instructions

Specify Container Size **

Identify Container Preservative Type***

Analysis Requested

Preservation non-conformance identified for sample:

Lab Use Only

Proj. Mgr: **Lori Beyer**

AcctNum / Client ID: **AR 70-102260**

Table #: **10367**

Profile / Template: **10367**

Preleg / Bottle Ord. ID:

Sample Comment

Sample ID	Date/Time	Obs. Temp. (°C)	Correction Factor (°C)	Corrected Temp. (°C)
MS-C2	10/31/24 6:25			
MS-GLR-A	10/31/24 6:30			
MS-A-DF-2	10/31/24 7:35			
MS-B-DF-1	10/31/24 7:25			
MS-B-DF-1-BF	10/31/24 7:25			
MS-DF-2	10/31/24 7:25			

Additional Instructions from Pace*:
Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number: **116 / 10:45 AM**
Delivered by: In-Person Courier
 FedEx UPS Other
Page: **5** of **5**

Client: Enter-Latvium
Middle School

Profile #: 10367

COC Page _____ of _____

Use Point Number Spreadsheet

Multiday Project

Add SCLOGFD to first sample for field charge

CCC Use Item	Matrix	VG9U	VG9C	VG9H	VG9S	VG9T	DG9Y	DG9P	DG9A	DG6T	DG8S	AG4U	AG3U	AG2U	AG1U	AG3A	AG34	AG3S	AG4E	AG3T	AG2R	AG1T	AG1H	AG1A	AG4A	CG1U	WG90	WG40	BP4U	BP3U	BP2U	BP1U	BP3S	BP2S	BP4N	BP3N	BP2N	BP3C	BP3T	BP35	BP3R	BP1Z	BP1N	BP1B	SP5T	R	WG2U	WG1U	WGKU	WGDU	ZPLC	GN	GN	WP	TEDL	BG1H	LLHG	BG1N	IOG	SOC
--------------	--------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	---	------	------	------	------	------	----	----	----	------	------	------	------	-----	-----

Container Codes

Container Codes	Glass	Plastic
VG9U	40mL unpres clear vial	BP4U 125mL unpres amber glass
VG9C	40mL Ascorbic HCl clear vial	BP3U 250mL unpres plastic
VG9H	40mL HCl clear vial	BP2U 500mL unpres plastic
VG9S	40mL Sulfuric clear vial	BP1U 1L unpres plastic
DG9T	40mL Na Thiosulfate vial	BP4N 125mL HNO3 plastic
DG9Y	40mL Citrate-Na Thiosulfate	BP3N 250mL HNO3 plastic
DG9P	40mL amber vial - TSP	BP2N 500mL HNO3 plastic
DG9A	Ascorbic/Maleic Acid 40mL	BP3S 250mL H2SO4 plastic
DG6T	Na Thio 60mL Vial	BP2S 500mL H2SO4 plastic
DG8S	Ammonium Cl/CuSO4 40mL	BP3C NaOH 250mL bottle
CG1U	1L Unpres Jar (Con E)	BP3T 250mL Trizma
WG90	8oz clear sol jar	BP3S 250mL Ammonium Acetate
WG40	4oz clear sol jar	BP3R 250mL NH4SC04-NH4CH
		BP1Z 1L NaOH, Zn Acetate
		BP1N 1L HNO3 plastic
		BP1B Na Thiosulfate Amber Bottle

Misc.
SP5T 120mL Collform Na Thio
R Terracore Kit
WG2U 2oz Unpreserved Jar
WG1U 4oz Unpreserved Jar
WGKU 8oz Unpreserved Jar
WGDU 16oz Unpreserved Jar
ZPLC Ziplock Bag
TEDL Tedlar Bag
BG1H 1L HCl Clear Glass
GN General
WP Wipe
LLHG Low Level Hig Bottles
BG1N 1L HNO3 Clear Glass

IOC
BP1U 1L unpreserved plastic
BP3N* 250mL HNO3 plastic
BP3C 250mL Sodium Hydroxide
AG2U 500mL unpres amber glass
BP3U 250mL unpreserved plastic

* Can only be a BP4N

Matrix
WT Water
SL Solid
NAL Non-aqueous Liquid
OL Oil
WP Wipe
DW Drinking Water

SOC
VG9T 40mL Na Thio amber vial
DG9A 40mL Ascorbic acid/maleic Acid vial
DG9Y Citrate/Na Thiosulfate 40mL
DG6T Na Thiosulfate 60mL vial
DG6M MonoChloric/Na Thio 60mL
AG3U 250mL unpres amber glass
AG3T Na Thiosulfate 250mL bottle
BP1B Na Thiosulfate Amber bottle
AG1T Na Thiosulfate 1L Amber
AG1A 525.3 Chemical Blend

Sender Initials AO

Additional Comments

Effective Date:

Client Name: INTER-LATHAM Project

WO#: 70321594

PM: LAB

Due Date: 11/21/24

CLIENT: INTER-LATHAM

Courier: Fed Ex UPS USPS Client Commercial Pack Other

Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No
Packing Material: Bubble Wrap Bubble Bags Ziploc Non Other Type of Ice: Wet Blue None

Thermometer Used: JH211 Correction Factor: ±0.3 Samples on ice, cooling process has begun
Cooler Temperature(°C): 18.4 Cooler Temperature Corrected(°C): 18.7 Date/Time 5035A kits placed in freezer _____

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: 11/22/24 EJ

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: <u>SL</u> <u>WT</u> <u>OIL</u> <u>OTHER</u>	

Date and Initials of person checking preservation: 11/22/24 EJ

All containers needing preservation have been <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>205324</u>	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH>12 Cyanide)	Initial when completed
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).	Lot # of added preservative:
Per Method, VOA pH is checked after analysis	Date/Time preservative added:
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #	Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #	15.
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Positive for Sulfide? Y N
Lead Acetate Strips Lot #	16.
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted: _____

Date/Time: _____

Comments/ Resolution: _____

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.